



Product Service

# CERTIFICATE

No. B 17 04 99241 001

**Holder of Certificate:** Newsun PV Technology Co.,Ltd

12A, 168 Building  
 Henggangtuo Industrial Zone  
 Xin'an Community, Chang'an Town  
 523883 Dongguan City, Guangdong Province  
 PEOPLE'S REPUBLIC OF CHINA

**Production Facility(ies):** 99241



**Certification Mark:**



**Product:** Connector  
 (Connectors for Photovoltaic System)

**Model(s):** 4C4000, 4C4001, 4P4000, 4P4001, 4B0000, 4B0001

**Parameters:**

Rated Voltage:	1000 V d.c.
Rated Current:	30 A
Protection Class:	II
Degree of Protection:	IP67
Ambient Temperature:	-40 °C to +85 °C

**Tested according to:** IEC 62852(ed.1)  
 EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 64290170020701

**Valid until:** 2022-04-17

**Date,** 2017-04-19

Page 1 of 1

*Harry Shubo Zhang*  
 (Harry Shubo Zhang)

