



U22 / 32 / N61.../N62... / H / PW / 2D / PQ / KLV / X

### Command and indicating devices

H	Heating	20 Watt 220 or 110V 50/60 Hz	
PV	Mushroom head push button latching	22 latching with indicating label	1 NC
P	Mushroom head push button	22 with indicating label	1 NO
D	Push button	22 with indicating label	1 NO
W	Selector switch 0-1	22 with indicating label	1 NO
L	Indicator light	22 with indicating label	Diode 24 Volt
L	Indicator light	22 with indicating label	Diode 230 Volt AC
	Contact block additional		1 S or 1 Ö
L	Indicator light	22 with indicating label	Diode 24 Volt protection IP65
L	Indicator light	10 with indicating label	Diode 24 Volt protection IP65

### Display devices

PQ	Powermeter PQ 72 1 mA DC	Engraved your instructions
PQI	Powermeter PQ 72 1 mA DC illuminated 24 Volt	Engraved your instructions
PQ	Powermeter PQ 72 x 36 1 mA DC	Engraved your instructions
PQI	Powermeter PQ 72 x 36 1 mA DC illuminated 24 Volt	Engraved your instructions
EQ	Amperemeter EQ 72 100/200/1A	Engraved your instructions
EQI	Amperemeter EQ 72 100/200/1A illuminated 24 Volt	Engraved your instructions
EQ	Amperemeter EQ 72 x 36 100/200/1A	Engraved your instructions
EQI	Amperemeter EQ 72 x 36 100/200/1A illuminated 24 Volt	Engraved your instructions

### Wiring

KLV on terminal block 2,5mm<sup>2</sup> with wire line 0,75 mm<sup>2</sup>

### Special model

X Special / customer specified

